



Meter Test Report

2208 S 14th St
 Mattoon IL 61938
 800-637-7121

Meter #	6321602	Form	2 S	Date	02/26/2021
Serial #	6321602	Kh	7.2	Invoice	4862248-00
AMR #	6321602	Test Volts	240.0	Tested By	117
Mfr	AB	Test Amps	30.00	KWH In	85190
Type	D5S	Test Station	6802	KWH Out	85190

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	MODULE READ 85188, METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	100.91%	100.91%						
LL	100.00%	100.00%						
Avg	100.46%	100.46%						



Meter Test Report

2208 S 14th St
Mattoon IL 61938
800-637-7121

Meter #	77767832	Form	2 S	Date	02/26/2021
Serial #	77767832	Kh	1.0	Invoice	4862248-00
AMR #	230012596	Test Volts	240.0	Tested By	117
Mfr	GE	Test Amps	30.00	KWH In	29912
Type	I-210+	Test Station	6802	KWH Out	29912

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	99.84%	99.84%						
LL	99.91%	99.91%						
Avg	99.88%	99.88%						



Meter Test Report

2208 S 14th St
Mattoon IL 61938
800-637-7121

Meter #	69680930	Form	2 S	Date	02/26/2021
Serial #	69680930	Kh	1.0	Invoice	4862248-00
AMR #	99094016	Test Volts	240.0	Tested By	117
Mfr	GE	Test Amps	30.00	KWH In	63666
Type	I-210+	Test Station	6802	KWH Out	63666

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	99.93%	99.93%						
LL	99.94%	99.94%						
Avg	99.94%	99.94%						



Meter Test Report

2208 S 14th St
Mattoon IL 61938
800-637-7121

Meter #	80355845	Form	2 S	Date	02/26/2021
Serial #	80355845	Kh	1.0	Invoice	4862248-00
AMR #	230065066	Test Volts	240.0	Tested By	117
Mfr	GE	Test Amps	30.00	KWH In	60294
Type	I-210+	Test Station	6802	KWH Out	60294

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	100.00%	100.00%						
LL	99.94%	99.94%						
Avg	99.97%	99.97%						



Meter Test Report

2208 S 14th St
Mattoon IL 61938
800-637-7121

Meter #	87599130	Form	2 S	Date	02/26/2021
Serial #	87599130	Kh	1.0	Invoice	4862248-00
AMR #	230963839	Test Volts	240.0	Tested By	117
Mfr	GE	Test Amps	30.00	KWH In	20577
Type	I-210+	Test Station	6802	KWH Out	20577

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	100.00%	100.00%						
LL	100.03%	100.03%						
Avg	100.02%	100.02%						



Meter Test Report

2208 S 14th St
 Mattoon IL 61938
 800-637-7121

Meter #	77769471	Form	2 S	Date	02/26/2021
Serial #	77769471	Kh	1.0	Invoice	4862248-00
AMR #	230057329	Test Volts	240.0	Tested By	117
Mfr	GE	Test Amps	30.00	KWH In	70629
Type	I-210+	Test Station	6802	KWH Out	70629

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	METER AND MODULE FUNTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	99.91%	99.91%						
LL	99.92%	99.92%						
Avg	99.91%	99.91%						



Meter Test Report

2208 S 14th St
Mattoon IL 61938
800-637-7121

Meter #	80018114	Form	2 S	Date	02/26/2021
Serial #	80018114	Kh	1.0	Invoice	4862248-00
AMR #	63096447	Test Volts	240.0	Tested By	117
Mfr	GE	Test Amps	30.00	KWH In	45202
Type	I-210+	Test Station	6802	KWH Out	45202

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	99.91%	99.91%						
LL	99.90%	99.90%						
Avg	99.91%	99.91%						



Meter Test Report

2208 S 14th St
Mattoon IL 61938
800-637-7121

Meter #	82889981	Form	2 S	Date	02/26/2021
Serial #	82889981	Kh	1.0	Invoice	4862248-00
AMR #	63666504	Test Volts	240.0	Tested By	117
Mfr	GE	Test Amps	30.00	KWH In	21670
Type	I-210+	Test Station	6802	KWH Out	21670

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	99.92%	99.92%						
LL	99.86%	99.86%						
Avg	99.89%	99.89%						



Meter Test Report

2208 S 14th St
Mattoon IL 61938
800-637-7121

Meter #	6948843	Form	2 S	Date	02/26/2021
Serial #	6948843	Kh	7.2	Invoice	4862248-00
AMR #	6948843	Test Volts	240.0	Tested By	117
Mfr	GE	Test Amps	30.00	KWH In	32119
Type	I60S	Test Station	6802	KWH Out	32119

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	MODULE READ 32119, METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	100.68%	100.68%						
LL	100.74%	100.74%						
Avg	100.71%	100.71%						



Meter Test Report

2208 S 14th St
Mattoon IL 61938
800-637-7121

Meter #	7753955	Form	2 S	Date	02/26/2021
Serial #	7753955	Kh	7.2	Invoice	4862248-00
AMR #	7753955	Test Volts	240.0	Tested By	117
Mfr	EL	Test Amps	30.00	KWH In	73688
Type	D5S	Test Station	6802	KWH Out	73688

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	MODULE READ 73687, METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	100.05%	100.05%						
LL	98.38%	98.38%						
Avg	99.22%	99.22%						



Meter Test Report

2208 S 14th St
 Mattoon IL 61938
 800-637-7121

Meter #	3948523	Form	2 S	Date	02/26/2021
Serial #	3948523	Kh	7.2	Invoice	4862248-00
AMR #	3948523	Test Volts	240.0	Tested By	117
Mfr	WH	Test Amps	30.00	KWH In	76198
Type	D5S	Test Station	6802	KWH Out	76198

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	MODULE READ 76197, METER AND MODULE FUNCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	100.10%	100.10%						
LL	100.08%	100.08%						
Avg	100.09%	100.09%						



Meter Test Report

2208 S 14th St
 Mattoon IL 61938
 800-637-7121

Meter #	15899352	Form	2 S	Date	02/26/2021
Serial #	15899352	Kh	7.2	Invoice	4862248-00
AMR #	15899352	Test Volts	240.0	Tested By	117
Mfr	AB	Test Amps	30.00	KWH In	43107
Type	D5S	Test Station	6802	KWH Out	43107

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	MODULE READ 43107, METER AND MODULE FUCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	100.41%	100.41%						
LL	100.55%	100.55%						
Avg	100.48%	100.48%						



Meter Test Report

2208 S 14th St
Mattoon IL 61938
800-637-7121

Meter #	6040170	Form	2 S	Date	02/26/2021
Serial #	6040170	Kh	7.2	Invoice	4862248-00
AMR #	6040170	Test Volts	240.0	Tested By	117
Mfr	AB	Test Amps	30.00	KWH In	48583
Type	D5S	Test Station	6802	KWH Out	48583

Customer	EAST CENTRAL OKLAHOMA COOP
Comments	MODULE READING 48581, METER AND MODULE FUCTIONING PROPERLY

Watt-hour test results

	Series		Element A		Element B		Element C	
	As Found	As Left	As Found	As Left	As Found	As Left	As Found	As Left
FL	100.92%	100.92%						
LL	100.23%	100.23%						
Avg	100.58%	100.58%						